




Product Service

CERTIFICATE

No. Z2 073899 0080 Rev. 02

Holder of Certificate: **ZNSHINE PV-TECH Co., Ltd.**
No.1, South Zhenxing Road
Industrial Zone, Zhixi Town, Jintan District
213251 Changzhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704061908310-02

Valid until: 2026-04-21

Date, 2021-04-23

(Zhulin Zhang)

CERTIFICATE

No. Z2 073899 0080 Rev. 02

Model(s):

ZXM6-78-xxx/M, xxx= 400 to 430 in steps of 5
ZXM6-72-xxx/M, xxx= 355 to 400 in steps of 5
ZXM6-66-xxx/M, xxx= 340 to 365 in steps of 5
ZXM6-60-xxx/M, xxx= 295 to 330 in steps of 5
ZXM6-NH156-xxx/M, xxx= 455 to 495 in steps of 5
ZXM6-NP156-xxx/M, xxx= 455 to 495 in steps of 5
ZXM6-NO156-xxx/M, xxx= 455 to 495 in steps of 5
ZXM6-NH144-xxx/M, xxx= 420 to 455 in steps of 5
ZXM6-NP144-xxx/M, xxx= 420 to 455 in steps of 5
ZXM6-NO144-xxx/M, xxx= 420 to 455 in steps of 5
ZXM6-NH132-xxx/M, xxx= 385 to 415 in steps of 5
ZXM6-NP132-xxx/M, xxx= 385 to 415 in steps of 5
ZXM6-NO132-xxx/M, xxx= 385 to 415 in steps of 5
ZXM6-NH120-xxx/M, xxx= 350 to 380 in steps of 5
ZXM6-NP120-xxx/M, xxx= 350 to 380 in steps of 5
ZXM6-NO120-xxx/M, xxx= 350 to 380 in steps of 5
ZXM6-NH156-xxx/M, xxx= 420 to 440 in steps of 5
ZXM6-NP156-xxx/M, xxx= 420 to 440 in steps of 5
ZXM6-NO156-xxx/M, xxx= 420 to 440 in steps of 5
ZXM6-NH144-xxx/M, xxx= 390 to 410 in steps of 5
ZXM6-NP144-xxx/M, xxx= 390 to 410 in steps of 5
ZXM6-NO144-xxx/M, xxx= 390 to 410 in steps of 5
ZXM6-NH132-xxx/M, xxx= 355 to 375 in steps of 5
ZXM6-NP132-xxx/M, xxx= 355 to 375 in steps of 5
ZXM6-NO132-xxx/M, xxx= 355 to 375 in steps of 5
ZXM6-NH120-xxx/M, xxx= 325 to 340 in steps of 5
ZXM6-NP120-xxx/M, xxx= 325 to 340 in steps of 5
ZXM6-NO120-xxx/M, xxx= 325 to 340 in steps of 5
ZXM6-H156-xxx/M, xxx= 415 to 435 in steps of 5
ZXM6-P156-xxx/M, xxx= 415 to 435 in steps of 5
ZXM6-H144-xxx/M, xxx= 380 to 405 in steps of 5
ZXM6-P144-xxx/M, xxx= 380 to 405 in steps of 5
ZXM6-H132-xxx/M, xxx= 355 to 370 in steps of 5
ZXM6-P132-xxx/M, xxx= 355 to 370 in steps of 5
ZXM6-H120-xxx/M, xxx= 320 to 335 in steps of 5
ZXM6-P120-xxx/M, xxx= 320 to 335 in steps of 5
ZXM6-NHDB156-xxx/M, xxx= 455 to 495 in steps of 5
ZXM6-NPDB156-xxx/M, xxx= 455 to 495 in steps of 5
ZXM6-NODB156-xxx/M, xxx= 455 to 495 in steps of 5
ZXM6-NHDB144-xxx/M, xxx= 420 to 455 in steps of 5
ZXM6-NPDB144-xxx/M, xxx= 420 to 455 in steps of 5
ZXM6-NODB144-xxx/M, xxx= 420 to 455 in steps of 5
ZXM6-NHDB132-xxx/M, xxx= 385 to 415 in steps of 5
ZXM6-NPDB132-xxx/M, xxx= 385 to 415 in steps of 5
ZXM6-NODB132-xxx/M, xxx= 385 to 415 in steps of 5
ZXM6-NHDB120-xxx/M, xxx= 350 to 380 in steps of 5
ZXM6-NPDB120-xxx/M, xxx= 350 to 380 in steps of 5
ZXM6-NODB120-xxx/M, xxx= 350 to 380 in steps of 5
ZXM7-SH156-xxx/M, xxx= 565 to 600 in steps of 5
ZXM7-SP156-xxx/M, xxx= 565 to 600 in steps of 5
ZXM7-SO156-xxx/M, xxx= 565 to 600 in steps of 5
ZXM7-SH144-xxx/M, xxx= 525 to 550 in steps of 5
ZXM7-SP144-xxx/M, xxx= 525 to 550 in steps of 5
ZXM7-SO144-xxx/M, xxx= 525 to 550 in steps of 5
ZXM7-SH132-xxx/M, xxx= 480 to 505 in steps of 5
ZXM7-SP132-xxx/M, xxx= 480 to 505 in steps of 5
ZXM7-SO132-xxx/M, xxx= 480 to 505 in steps of 5
ZXM7-SH120-xxx/M, xxx= 435 to 460 in steps of 5
ZXM7-SP120-xxx/M, xxx= 435 to 460 in steps of 5
ZXM7-SO120-xxx/M, xxx= 435 to 460 in steps of 5
ZXM7-SH108-xxx/M, xxx= 395 to 415 in steps of 5
ZXM7-SP108-xxx/M, xxx= 395 to 415 in steps of 5
ZXM7-SHDB156-xxx/M, xxx= 565 to 600 in steps of 5
ZXM7-SPDB156-xxx/M, xxx= 565 to 600 in steps of 5
ZXM7-SODB156-xxx/M, xxx= 565 to 600 in steps of 5
ZXM7-SHDB144-xxx/M, xxx= 525 to 550 in steps of 5
ZXM7-SPDB144-xxx/M, xxx= 525 to 550 in steps of 5
ZXM7-SODB144-xxx/M, xxx= 525 to 550 in steps of 5
ZXM7-SHDB132-xxx/M, xxx= 480 to 505 in steps of 5
ZXM7-SPDB132-xxx/M, xxx= 480 to 505 in steps of 5



CERTIFICATE

No. Z2 073899 0080 Rev. 02

ZXM7-SODB132-xxx/M, xxx= 480 to 505 in steps of 5
 ZXM7-SHDB120-xxx/M, xxx= 435 to 460 in steps of 5
 ZXM7-SPDB120-xxx/M, xxx= 435 to 460 in steps of 5
 ZXM7-SODB120-xxx/M, xxx= 435 to 460 in steps of 5
 ZXM7-SHDB108-xxx/M, xxx= 395 to 415 in steps of 5
 ZXM7-SPDB108-xxx/M, xxx= 395 to 415 in steps of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790
Severity of Salt mist test:	Severity 6

Tested according to:

IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 IEC 61701:2011